Products Declaration - DGNB Neubauversion Büro- und Verwaltungsgebäude (NBV09)

Manufacturer Adolf Würth GmbH & Co. KG

Product Name Ventilation Duct Sealant (0892 325 1)

### **Product Rating**

• The product fulfills the requirements of action level 1 to 4 and contributes to achieve 10 (of max. 10) criterion points within Criterion 06 'Risks for the regional environment'.

# Criterion 06 Risks for the Local Environment - Ecological Quality

Action Level 1 1 Point

V

Action Level 2 5 Points

 $\checkmark$ 

Action Level 3 7.5 Points

 $\checkmark$ 

Action Level 4 10 Points

# $\checkmark$

## Criterion 08 Sustainable Resources - Ecological Quality\*

Action Level 1 5 Points



Action Level 2 7.5 Points



Action Level 3 10 Points



#### **Product Characteristics**

Acrylic resin dspersion. Neutral- odor, elastic special sealant for the sealing of ventilation ducts in bulidings and equipment, as well as air ehaust system in large scale catering kitchens.

#### About DGNB Products - www.dgnb.de

This declaration helps to assess products easily according the certification system DGNB® Neubauversion Büro- und Verwaltungsgebäude (NBV09). Products are not reviewed or certified by DGNB. DGNB credit requirements cover the performance of materials in aggregate, not the performance of individual products or brands. Therefore the project team or the manufacturer is responsible to declare the compliance with the project requirements to achieve DGNB points.

Below you find an explanation of the symbols. Detailed information are on the next pages.

- Credit requirements fulfilled the action level is achieved
- O Credit is not applicable to this product
- 22% X% of the product comply with the credit requirement
- Required data not specified for required data contact manufacturer
- Credit requirements are not fulfilled

<sup>\*</sup> This criterion is only applicable to wooden materials.

Products Declaration - DGNB Neubauversion Büro- und Verwaltungsgebäude (NBV09)

Manufacturer Adolf Würth GmbH & Co. KG

Product Name Ventilation Duct Sealant (0892 325 1)

# Criterion 06 Risks for the Local Environment - Ecological Quality

#### **Detailed Rating**

No	Product Name		Manufacturer	
A1	Ventilation Duct Sealant (0892 325 1)		Adolf Würth GmbH & Co. KG	
Product Type		Requirement		Contribution of Product
Sealants, adhesives, and anti-corrosion		Action Level 4: VOC-content < 3% Action Level 3: VOC-content < 10%		N00 1 1 200
Applied on mineral and non-mineral			el 2: VOC-content < 15%; RAL UZ 12a count as proof el 1: VOC-content < 25%	VOC-content: 0%